

NOTICE TO THE PUBLIC

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Aqua Pennsylvania Midway (PWSID# PA2400104)

Parts of Kingston and Dallas townships, Shavertown, Trucksville and Wyoming

BOIL WATER NOTICE LIFTED

ESTE INFORME CONTIENE INFORMACIÓN MUY IMPORTANTE SOBRE SU AGUA POTABLE.

TRADÚZCALO O HABLE CON ALGUIEN QUE LO ENTIENDA BIEN

The Boil Water Notice issued on Monday, January 28, 2019 has been lifted effective today, Wednesday, January 30, 2019, for the Midway Water System.

What happened? What is being done? When will the problem be corrected?

On January 28, 2019, Aqua Pennsylvania staff at its White Haven Division were alerted by alarm that its Midway Manor tank levels were dropping quickly. Emergency personnel responded and found that a pressure relief valve had failed, causing a pressure drop in the distribution system. The problem was isolated, but not before experiencing a loss of positive pressure in the distribution system resulting in a boil water notice for customers in the Midway Manor System. Two sets of samples were collected from the distribution system on Monday, January 28 and Tuesday, January 29 and tested for total coliform bacteria. Satisfactory bacteriological results were received on Wednesday, January 30, 2019.

It is no longer necessary to use boiled water or bottled water for drinking, making ice, brushing teeth, washing dishes and food preparation.

Aqua is committed to providing quality water and service to its customers. We apologize for the inconvenience and thank you for your patience. Although this matter has been resolved, if you have any questions or concerns, please contact Aqua's Customer Service at 877.987.2782.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For more information, please contact:

Responsible Person Dave Hoogstad, Field Supervisor	System Name Midway Manor	Address (Street) 1 Aqua Way
Phone Number 877.987.2782	System PWSID# PA2400104	Address (City, State, Zip) White Haven, PA 18661

Date Notice Distributed: January 30, 2019

Date Notice Lifted: January 30, 2019